

Missouri
Department
of Transportation



Roger Schwartz, District Engineer

Central District
1511 Missouri Boulevard
P. O. Box 718
Jefferson City, MO 65102
(573) 751-3322
fax (573) 522-1059
Toll free 1-888 ASK MoDOT
www.modot.org

IMPORTANT BID CHANGES

December 22, 2009

RE: Addendum 02 to Bid D5-10-045B, Fuel Tanks

Dear Bidders:

Please note that this addendum letter is to inform all potential bidders of the following changes to bid D5-10-045B. Please read the clarification below.

Current Specs read:

Each tank will be fitted with two (2) 8 inch Morrison Type or equivalent emergency vents, (one primary and one interstitial), rated at 16 oz/sq in.....

Should read:

Each tank will be fitted with two (2) 6 inch Morrison Type or equivalent emergency vents, (one primary and one interstitial), rated at 8 oz/sq in.....

Bid opening will remain on December 30, 2009 at 1:00 PM CST.

Addendum must be signed and returned with bid.

If you have any questions, please call.

By signing, _____, I fully understand the addendum request.
Vendor

Date _____

Thank you!

Corey Duemmel
Sr. Procurement Agent
D5 General Services
(573) 526-6956