

**ADDENDUM 001  
REQUEST FOR QUOTE  
Purchase and Installation of Wireless Lighting Alarm for (3) FAA  
Lighted Sites  
RFQ# D7-10-022**

Bidders/Offerors shall acknowledge receipt of Addendum 001 (ONE) by signing and mailto: [Christina.Stephens@modot.mo.gov](mailto:Christina.Stephens@modot.mo.gov) including it with the original quote. The due date for receipt of quotes has changed by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders/Offerors. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Chris Stephens Intermediate Procurement Agent
Bidder/Offeror Signature   <hr/> (Signature of person authorized to sign)	Department of Transportation   <i>Chris Stephens</i> <hr/> (Authorizing Signature)
Date Signed:	Date Signed: <b>12/8/09</b>

**QUESTIONS/CLARIFICATIONS**

**01) Due Date of Quote has changed from December 9, 2009 to December 18, 2009**

**002) Height and Coordinates for Jerico Springs Tower**

**Height 285' Guyed**  
**Coordinates: LAT: 37-36-42.2 N**  
**LONG: 94-0-33.8 W**  
**Elev: 320.0 ft**

**Powered:** There is electrical power available, with emergency power available also.

**003) Height and Coordinates for Avilla Tower**

**Height 265' Guyed**  
**Coordinates: LAT: 36-42-3.2 N**  
**LONG: 94-1-24.7 W**  
**Elev: 451.0 ft**

**Powered:** There is electrical power available, with emergency power available also.

#### **004) Third Locations is Shell Knob Bridge**

This location is not a tower, it is a roadway bridge over Table Rock lake that has Aviation navigation lights on the sides of it, due to small aircraft flying under it. There is utility electrical power, but if there is a power outage, there would be no power at all. This consists of 2 lights that are on all the time, power is provided from a disconnect at the south end of the bridge. There is no relays, or voltage sensing equipment. Coordinates and Height not available at this time. Please contact Buyer above if additional information is required.

**005) Pagers:** We already have a numerical pager that we will be using. We will need to receive a numerical page only. The number we receive will either need to be; a number associated with that site, or a number to a monitoring center that when we call them will tell us which site is faulted.

There are no phone lines at any of these sites.